

## THE ADMINISTRATION OF UNION TERRITORY OF LADAKH

## OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No: 01982-260888) No: PHQ/ Dir/F&ES/UTL/2022-2649 Dated: 28/12/2022

## Subject: Fire NOC of Islamia Public High School, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the School which has been done by DFO Fire and Emergency Services, Leh. The detailed report is as under:

The School building is constructed at, Leh. It is located at Longitude 77.577435 and Latitude 34.145783. The site is Location/ Accessibility: approximately 03 Kms from Fire and Emergency Services Station, Leh. It takes approximately 06 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The School building have 09 blocks. The detail of the block is as under:

1st block: It is two storied building having two staircase. In the ground floor there are 5 number of class rooms. There are two windows in each room and the size is 8x8 feet and 3x5 feet. Two side of the windows have provision to open. 1st

2<sup>nd</sup> block: It is single storied building having multipurpose hall. There are six number windows and 5 exits doors. The size of the windows have 8x8 feet. Two side of the windows have provision to open.

3rd block: It is two storied building having two staircase. In the ground floor there are 5 number of class rooms. There are one window in each room and the size is 5x10 feet. Two side of the windows have provision to open. 1st floor have 5

4th block: It is two storied building having two staircase. In the ground floor there are 2 number of class rooms. There are one window in each room and the size is 8x8 feet. Two side of the windows have provision to open. 1st floor have two

5th block: It is single storied hostel building having 4 number of barracks. There are two windows in each barrack and the size is 8x10 feet. Two side of the windows have provision to open.

6th block: It is single storied building having sport room. There are 07 number of windows and the size is 3x7 feet. Two side of the windows have provision to open.

7th block: It is single storied building having 3 number of laboratory rooms. There are two windows in each room and the size is 4x5 feet. Two side of the windows have provision to open.

8th block: It is two storied building having two staircase. In the ground floor there are canteen and a room. There are two windows in each room and the size is 4x5 feet and 3x2 feet. Two side of the windows have provision to open.

9th block: It is two storied building having two stair case. In the ground floor there are staff room, account office and medical room. There are two windows in each room and the size is 4x4 feet and 8x10 feet. Two side of the windows have provision to open. 1st floor have Principal office, Chairman office and examination hall.

The following Fire Safety equipment's which are installed in School Building:

- 01. 30 no's of fire extinguisher ABC Type 5 kg capacity is installed in the school building.
- 02. 03 number of submersible bore in the premises of the school building.
- 03. 16 number of plastic water tank 500 liters capacity is installed in the school premises.
- 04. 10 thousand liters underground reserve water tank is installed in the school premises.
- 05. Six number of sand bucket is installed in the school premises.
- 06. Smoke detector is installed in the hostel building.

FIRE NOC is given in favour of Islamia Public High School, Leh for period of One year from the issuance.

Director, F&ES, Ladakh PHQ, Agaling, Leh

01. Principal/Islamia Public High School, Leh for information and n/a.

02. Superintendent of Police, F&ES, Ladakh for information,

03. Office file we

School Islamia |

Islamia Public School

Leh - Ladakh

School Managing Committee, Islamia Public School, Leh